



The Automated Flow and Level Control Trainer is the system, which outlines the basics of Feedback Flow and Feedback Level Control Loops.

**KEYWORDS**

- ❖ Feedback Control
- ❖ Feedback Level Control
- ❖ Feedback Flow Control
- ❖ PID Control
- ❖ P, P+I, P+I+D Controller Action

**Technical Specification:**

- ❖ Sump tank: - Material: Stainless Steel, 2 mm thick/P.P.5mm thick , Capacity: 30 liters, Dimension: 1ft (L) × 1ft (W) × 1ft (H).
- ❖ Level Tank: - Dimension: 150(Ø) mm×400(H) mm.
- ❖ Piping: - ½” Class B GI, with ½” SS ball valves: 10 No.
- ❖ Centrifugal Pump: - ¼ H.P., 230 V AC supply, Surface mounting.
- ❖ Flowmeter: - ½”, turbine type / wfm type, Range: 0-600 LPH / 0-1000 LPH.  
Output: 4-20 mA, Type: 3-wire type, Supply: 24 V DC: 100 mA  
Mounting: Horizontal, Connection: ½”
- ❖ Level Transmitter: - Input: 0-400 /0-500 mm, Output: 4-20 mA  
Supply: 24 V DC: 100 mA Type: 2-wire  
Capacitance type, Type, Mounting: Top 2” screwed connection.
- ❖ Pneumatic control valve: - Size: ½”, Type; Two way Globe type (Air to Close)  
Cv: 5 US GPM, with diaphragm actuator.  
Flange connection: PCD: 60 mm, ID16 mm, OD: 90 mm.
- ❖ Rotameter: - 2 no. Range: 0-1000 LPH, Glass tube type/ Acrylic body, Connection: ½”,  
Bob material: SS 304, Mounting: Inlet Bottom Outlet Top.
- ❖ E/P Converter: - Input: 4-20 mA, Output: 3-15 psi, Connection: ¼” NPT / BSP.
- ❖ Air pressure Regulator: - 0-10 Kg/cm<sup>2</sup> with pressure gauge, Connection: ¼” NPT / BSP.
- ❖ Electronic PID Controller: - 2 no. Single input PID (1 NO.) & Dual input (1 No.),  
With Serial PC Interface (ASCII Protocol) RS 232,  
Cut Out Size: 92mm×92mm×144mm, Input: 4-20 mA, Output: 4-20 mA,  
Display: Dual for PV & SP, Bar graph display for  
Output & deviation. Hi-Low Alarm annunciation.

- ❖ SCADA Application  
Software: - SCADA S/W, PID control setting (P, PI, PD and PID mode),  
(Optional) Auto/Manual Tuning of PID, Data Storage, Off Line analysis, Online Data Acquisition, Simulation and Printing of data in Graphical and tabular form. Interactive Graphical User Interface (GUI) includes.
- ❖ Electrical Control Panel: -MS Powder coated panel with switches, Indicator, test Points, Controller on front facia, UK 2.5 Terminal Connectors mounted on DIN rail Channel.  
Dimension: 1ft (L) × 1ft (W) × 1ft (H)
- ❖ Computer: - PC with colour monitor: 15'', PC Pentium Dual Core,  
(Optional) With serial communication ports, 80 GB HDD, 512 MB RAM, Floppy Drive.
- ❖ Air Compressor: - Tank capacity: 30 Liters, Discharge: 2 CFM  
(Optional) Motor: ½ H.P. 230 V AC Operated, Working pressure: 3-4 kg/cm<sup>2</sup>

**Features:**

- ❖ Compact Ergonomic Design.
- ❖ User Friendly, Self Explanatory Systems.
- ❖ Leak proof Safety Measures, Sturdy Piping & Robust Construction.
- ❖ Enhanced Electrical Safety Considerations.
- ❖ Training Manuals & mimic Charts for Operation Ease.
- ❖ System Frame with Caster Wheel Arrangement for ease in movement.
- ❖ M.S. powder coated cubical plant with standard Instrument Mountings.
- ❖ Inbuilt Safety Measures to avoid improper usage.
- ❖ Computer Interface & SCADA software connectivity for analysis of Cascade Control Loop (Optional).

**Range Of Experiments:**

- ❖ Study of Feedback Control.
- ❖ Study of single loop proportional (P), integral (I), and derivative (D) control.
- ❖ Study of operation and calibration of transmitters, I/P converter and pneumatic control valve.
- ❖ Study of programming and operation of PID controller.
- ❖ Study of Feedback Flow Control loop and Feedback Level Control loop.
- ❖ Study of rotameter, capacitance type level sensor & control valve.
- ❖ Study of SCADA Application Software/ Computerized Control of Cascade Control System.
- ❖ Auxiliary Experiments.


**System Dimensions:** 4.5 Ft. (L) X 1.5 Ft. (W) X 4.5 Ft. (H)

**Services Required:**

- ❖ Electric supply 230VAC, 50Hz.
- ❖ Clean, dry Compressed air supply at 2.1 Kg/cm<sup>2</sup>.

**Note:**

All descriptive matter and illustrations above are intended to give only a general idea of the equipments. Detailed specifications may be altered at the company's discretion without any notice.

<b>Manufactured / Marketed by</b>		
<b>SAP ENGINEERS AND CONSULTANTS</b>		
<b>Regd. Off.</b>	: Shop No. 26, 27 Srushti, S. No. 82/11+12++33+34, Eklavya Clg Rd (D. P. Road), Kothrud, Pune- 38	
<b>Telephone</b>	: (020) 25384737	
<b>Mobile</b>	: (+91) 9422088946, 9552475082	
<b>Fax</b>	: (020) 25383544	
<b>Email</b>	: <a href="mailto:pravinsdeode@vsnl.net">pravinsdeode@vsnl.net</a>	
<b>Website</b>	: <a href="http://www.sapengineers.com">www.sapengineers.com</a> / <a href="http://www.sapengineers.co.in">www.sapengineers.co.in</a>	