

**SAP E&C CASCADE CONTROL SYSTEM TRAINER
(PCST 05) COMPUTERIZED (OPTIONAL)**



The Cascade Control System Trainer is the system, which outlines the basics of Cascade Control considering Flow, Level as Pressure parameters.

KEY WORDS :

- ❖ Feedback Control
- ❖ Cascade Control (Flow + Level).
- ❖ Feedback Flow Control.
- ❖ Feedback Level Control
- ❖ PID control.
- ❖ P, P+I, P+I+D Controller Action

Technical Specification:

- ❖ Sump tank: - Material: Stainless Steel, 2 mm thick/P.P.5mm thick , Capacity: 30 liters, Dimension: 1ft (L) ×1ft (W) ×1ft (H).
- ❖ Level Tank: - Dimension: 150(Ø) mm×400(H) mm.
- ❖ Piping: - ½” Class B GI, with ½” SS ball valves: 10 No.
- ❖ Centrifugal Pump: - ¼ H.P., 230 V AC supply, Surface mounting.
- ❖ Flowmeter: - ½”, turbine type / wfm type, Range: 0-600 LPH / 0-1000 LPH. Output: 4-20 mA, Type: 3-wire type, Supply: 24 VDC: 100 mA Mounting: Horizontal, Connection: ½”
- ❖ Level Transmitter: - Input: 0-400 /0-500 mm, Output: 4-20 mA Supply: 24 VDC: 100 mA Type: 2-wire Capacitance type, Type, Mounting Top 2” screwed connection.
- ❖ Level Switch: - Float operated, Float Material: SS304, Switching Current: 2A Switching voltage: 240 VAC\200 VDC Switch Action: Reversible, Weight: 315 Gms
- ❖ Pneumatic control valve: - Size: ½”, Type; Two way Globe type (Air to Close) CV: 5 US GPM, with diaphragm actuator. Flange connection: PCD: 60 mm, ID16 mm, OD: 90 mm.
- ❖ Rotameter: - 2 no. Range: 0-1000 LPH, Glass tube type/ Acrylic body, Connection: ½”, Bob material: SS 304, Mounting: Inlet Bottom Outlet Top.
- ❖ E/P Converter: - Input: 4-20 mA, Output: 3-15 psi, Connection: ¼” NPT / BSP.
- ❖ Air pressure Regulator: - 0-10 Kg/cm² with pressure gauge, Connection: ¼” NPT / BSP.
- ❖ Electronic PID Controller:- 2 no. Single input PID (1 No.) & Dual input (1 No.), With Serial PC Interface (ASCII Protocol) RS 232, Cut out Size: 92mm×92mm×144mm, Input: 4-20 mA, Output: 4-20 mA, Display: Dual for PV & SP, Bar graph display for Output & deviation. Hi-Low Alarm annunciation.

- ❖ SCADA Application
Software: - SCADA S/W, PID control setting (P, PI, PD and PID mode),
(Optional) Auto/Manual Tuning of PID, Data Storage, Off Line analysis, Online Data Acquisition, Simulation and Printing of data in Graphical and tabular form. Interactive Graphical User Interface (GUI) includes.
- ❖ Electrical Control Panel: -MSPowder coated panel with switches, Indicator, test Points, Controller on front facia, UK 2.5 Terminal Connectors mounted on DIN rail Channel.
Dimension: 1ft (L) ×1ft (W) ×1ft (H)
- ❖ Computer: - PC with colour monitor: 15'', PC Pentium Dual Core,
(Optional) With serial communication ports, 80 GB HDD, 512 MB RAM, Floppy Drive.
- ❖ Air Compressor: - Tank capacity: 30 Liters, Discharge: 2 CFM
(Optional) Motor: ½ H.P. 230 V AC Operated, Working pressure: 3-4 kg/cm²

Features:

- ❖ Compact Ergonomic Design.
- ❖ User Friendly, Self Explanatory Systems.
- ❖ Leak proof Safety Measures, Sturdy Piping & Robust Construction.
- ❖ Enhanced Electrical Safety Considerations.
- ❖ Training Manuals & mimic Charts for Operation Ease.
- ❖ System Frame with Caster Wheel Arrangement for ease in movement.
- ❖ M.S. powder coated cubical plant with standard Instrument Mountings.
- ❖ Inbuilt Safety Measures to avoid improper usage.
- ❖ Computer Interface & SCADA software connectivity for analysis of Cascade Control Loop (Optional).

Range Of Experiments:

- ❖ Study of multivariable loop, Cascade Control.
- ❖ Study of single loop proportional (P), integral (I), and derivative (D) control.
- ❖ Study of operation and calibration of transmitters, I/P converter and pneumatic control valve.
- ❖ Study of programming and operation of PID controller.
- ❖ Study of stability of dual loop cascade control system (Flow - Level Control).
- ❖ Study of rotameter, capacitance type level sensor & control valve.
- ❖ Study of SCADA Application Software/ Computerized Control of Cascade Control System.
- ❖ Auxiliary Experiments.

System Dimensions: 4.5 Ft. (L) X 1.5 Ft. (W) X 4.5 Ft. (H)

Services Required:

- ❖ Electric supply 230VAC, 50Hz.
- ❖ Clean, dry Compressed air supply at 2.1 Kg/cm².

Note:

All descriptive matter and illustrations above are intended to give only a general idea of the equipments. Detailed specifications may be altered at the company's discretion without any notice.

| | | |
|--------------------------------------|---|---|
| Manufactured / Marketed by | |  |
| SAP ENGINEERS AND CONSULTANTS | | |
| Regd. Off. | : Shop No. 26, 27 Srushti, S. No. 82/11+12++33+34, Eklavya Clg Rd (D. P. Road), Kothrud, Pune- 38 | |
| Telephone | : (020) 25384737 | |
| Mobile | : (+91) 9422088946, 9552475082 | |
| Fax | : (020) 25383544 | |
| Email | : pravinsdeode@vsnl.net | |
| Website | : www.sapengineers.com / www.sapengineers.co.in | |